

# NASA Contractor Report 166007

NASA-CR-166007  
19820019246

OCULOMETER FOCUS AND MIRROR CONTROL

Warren J. Guy

LAFAYETTE COLLEGE  
Easton, Pennsylvania 18042

Grant NAG1-45  
October 1982



**LIBRARY COPY**

OCT 26 1982

LANGLEY RESEARCH CENTER  
LIBRARY, NASA  
HAMPTON, VIRGINIA



National Aeronautics and  
Space Administration

**Langley Research Center**  
Hampton, Virginia 23665

## CONTENTS

	<u>Page</u>
1. INTRODUCTION	1
2. FOCUS CONTROL	4
2.1 SYSTEM OVERVIEW	6
HARDWARE	6
SOFTWARE	10
2.2 FOCUS COMMAND TABLE	13
OPTICAL SYSTEM	13
RANGE-TIME RELATIONSHIP	15
FOCUS TABLE	15
2.3 FOCUS TABLE ADJUSTMENTS	18
2.4 ELECTRONIC CIRCUIT	20
2.5 SOFTWARE	26
3. TRACKING CONTROL	38
3.1 SYSTEM OVERVIEW	39
HARDWARE	39
SOFTWARE	42
3.2 ELECTRONIC CIRCUIT	46
3.3 SOFTWARE	55
4. CONCLUSIONS	61
REFERENCES	63

# FIGURES

	<u>Page</u>
1. Range error induced look point offset	5
2. Automatic Focus System basic structure	7
3. Oculometer automatic focus system block diagram	8
4. Oculometer automatic focus flow chart	11
5. Optical system for demonstration unit	14
6. Range/Count Relationship	16
7. Voltage for focus command (DAC output, manual, and theoretical) vs. Range	17
8. Interface circuit for Polaroid Ultrasonic Range Measuring System. From Polaroid Handbook	21
9. Part 1, microcomputer board. Pulse shaping (74123), microcomputer (8748), and DAC (1408-741)	23
10. Electronic Controller and focus error indicator circuits	25
11. Display Circuit, Input from Port 2, 8748 via flat 16 conductor cable	27
12. Power cable and servo cable pin connection	28
13. Oculometer automatic focus memory map	29
14. Tracking system geometry	40
15. Automatic Tracking System block diagram	41

16.	Automatic Tracking System flow chart	44
17.	X ultrasonic board with buffer and rate controller	47
18.	Y ultrasonic board with buffer	49
19.	Wave shaping circuit (74123) and microcomputer (8748)	50
20.	DAC output (1408-741)	52
21.	Regulated supply for manual joy stick control	53
22.	Cable connections for Automatic Tracking System	54
23.	Automatic Tracking System Memory map	56

# OCULOMETER FOCUS

AND

# MIRROR CONTROL

by

Warren J. Guy

## 1. Introduction

Since 1970 the Flight Dynamics and Control Division at the National Aeronautics and Space Administrations' Langley Research Center, Hampton, Va., has been engaged in a research program employing a remote sensing oculometer. The purpose of this program has been to gather and analyze dynamic data collected about pilot eye behavior. Ultimately it is hoped that this research will lead to strategies for optimal aircraft instrument panel design and better pilot training (1,2,3).

The heart of this research is built around the oculometer, a nonintrusive eye tracking instrument. The unit employs a safe infrared (IR) beam which is reflected off the retina and cornea to produce an image picked up by an IR sensitive video system. The picture is digitized and pertinent information processed by a mini-computer (4). The "look point" is the primary output of the system; however, other functions must also be performed by the computer.

As the subject's eye and/or head moves, it is necessary to maintain the eye image nearly centered in the TV field. This is accomplished with two mirrors orthogonally oriented which direct the IR beam to the subject and receive the reflected eye image. The mirrors, driven by galvanometer motors, are controlled by the minicomputer. The computer generates a control signal based on the motion of the eye as detected by the video signal. Often, due to sudden voluntary motion or involuntary motion caused by turbulence, the eye image is lost. At this point the tracking system must go into a lengthy and not always successful searching routine to recapture the eye image. During this search period all the data is lost, and depending upon conditions, well over 10% of the experiment time could be taken by searching.

In the normal computational process, the computer has 1/60th second between fields to find the look point and output the necessary control signals to the system peripheral

) equipment like the mirrors. The program requires a great deal of time (usually greater than 1/60th second) to perform its tasks. Due to the structure of the software, this means that alternate fields are lost. When this occurs, it is possible to lose track and thus be forced into a search mode.

The system as it is currently configured requires the constant attention of a highly skilled operator. It is his function to accelerate the search process, keep the optical system focused, determine the record linearization data for each experiment and maintain the equipment. Thus, work has been undertaken to speed up the computational process, miniaturize the oculometer system, unburden the main computer and reduce the operator skill level and intensity. To this end, this report discusses methods to decrease the required operator attention through automatic focusing and tracking. An important by-product of this effort is that the subject's range is constantly updated; thus providing the computer with data so that a more accurate look point can be calculated.

## 2. FOCUS CONTROL

The distance to the subject from the reference plane on which the look point is desired is determined in the NOVA computer by processing the voltage off the focus command (FC) potentiometer. This pot is manually adjusted by the operator as the subject moves his head position. While this chore is not overly burdensome, inaccurate focusing can lead to a fuzzy image, the possibility of losing track, and incorrect look point calculation.

The inaccurate look point can be caused by improper focus and the subsequent computational error produced in the corneal high light - pupil relationship. It can also be induced by an inaccurate measurement range; this latter type error will be considered. Figure 1 shows a y look point error,  $\Delta y$ . As can be seen from the figure, if the real range is R and there is a negative error,  $\Delta R$ , the look point will be calculated higher by the amount

$$\Delta y = \Delta R \sin \theta$$

For a nominal range error of 2 inches and  $\theta = 10^\circ$ , the look point error could be 0.35 inches.






FIGURE 1. Range error induced look point offset.

Thus an automatic focusing mechanism for the oculometer will reduce these errors because more accurate range data will be available to the computer. Also, a sharp image will be maintained at all times.

To accomplish the automatic focus control, a simple position feedback control system is used, figure 2. An ultrasonic range detector and microprocessor develop the focus command. This signal (along with a potentiometer position feedback voltage) drives a standard servomechanism error amplifier. A power amplifier controls the small dc servomotor.

In the next section a systems overview of both the hardware and the software will be given. Then the focus table development will be described. Finally a detailed description of the electronics and microprocessor program will be presented.

## 2.1 SYSTEM OVERVIEW

HARDWARE: Figure 3. The range detector employs a commercially available ultrasonic ranging system (5), which consists of a capacitive microphone and a transceiver board. The unit must be supplied with a 6V, 3A (minimum) power supply and an external circuit to control the repetition rate of the transmit/receive cycle. The unit produces two output




FIGURE 2. Automatic Focus System basic structure.





FIGURE 3. Oculometer automatic focus system block diagram

pulses on separate lines, one when the transmitter is turned on and the other when an echo is received. The rate control must allow sufficient time for the ultrasonic pulse to travel to and return from the target. The specifications limit the time between transmit pulses to 40 msec.; the prototype automatic focus system is designed for a 100 msec. cycle time.

An interface board buffers the ranging system and control circuits. The transmit and echo pulses are next passed through the pulse shaper where they are cleaned up and gated to prevent false echos which would interrupt the microprocessor. Using an on-board timer, the microcomputer measures the time to the target, filters the data, generates a range count for display purposes and outputs a digital focus command (FC). The digital command is then converted to analog form.

The error amplifier can be switched between a manual and automatic focus control signal. In the manual mode, a simple potentiometer changes the focus. This is the way focus is currently adjusted. The FC command (manual or automatic) is compared with the lens position via a feedback potentiometer and a signal developed to drive a power amplifier. The final element in the system is the mechanical parts; motor, gears, and load.

When the system is out of focus, an indicator light is turned on.

SOFTWARE: Figure 4 shows the flow chart for the micro-computer program. A manual reset starts the program by clearing the appropriate working registers. The on-board timer is then cleared (START) and the subroutines SHOW and DISPLAY called. These two subroutines decode the binary range count (the round-trip time to the target) to a 3 digit BCD Code which is cycled through hundreds, tens, and units; the display is held on until the transmit pulse is sent. At this time the timer is activated (TIME) and the interrupt enabled. While waiting for the echo (typically 4 to 6 msec), the previous binary range count is converted to a decimal format by DISPLAY. The program continues its wait by returning to the SHOW and DISPLAY subroutines.

Upon the arrival of the echo, the microcomputer is interrupted (STOP), the timer stopped and checked. If the count is too large (greater than  $90_{10}$ ) the target is out of range and the maximum distance ( $90_{10}$ ) is substituted for the range count.

The range count is now filtered by a simple digital filter algorithm (FILTER):

$$OUT(I) = OUT(I-1) + \frac{COUNT(I) - OUT(I-1)}{4}$$

where

COUNT (I) = the range count (typically  $30_{10} - 90_{10}$ )

COUNT (I) = the new filter output

OUT (I-1) - the previous filter output




FIGURE 4. Oculometer automatic focus flowchart

Finally OUT(I) is used to look up in a focus table the actual binary focus command (FC). This information is next latched into PORT 1. The program then cycles back to START where the whole process is repeated.

If the timer should overflow due to a malfunction or the lack of a target, the system ignores the range data and returns to START.



## 2.2 FOCUS COMMAND TABLE

OPTICAL SYSTEM: The optical system to be controlled is shown in figure 5. Here the ground glass plate, built into the demonstration model, would be the active surface of the TV camera in the oculometer. Lens F2 is mounted in a movable lens carriage. It is the distance L2 that will be controlled by the servomechanism. F1 is a fixed lens located a distance L1 from the plate. The subject is at a range R from the optical system.

The equation governing the relationship between the system variables is stated below:

$$F1 \cdot R = (R - F1) \cdot (L1 - L2 + (F2 \cdot L2 / (F2 + L2)))$$

where F1 = focal length of lens 1 (nominally 95mm)

F2 = focal length of lens 2 (nominally -29mm)

R = range to subject (nominally 600 to 1200mm)

L1 = fixed distance - lens 1 to plate (nominally 160mm)

L2 = variable distance - lens 2 to plate (nominally 60mm)

Rearranging the equation to find L2 in terms of range R gives the nonlinear relationship:

$$L2^2 + (F1 / (R - F1) - L1) \cdot L2 + (F1 \cdot R / (R - F1) - L1) \cdot F2 = 0$$

Because the computation of L2, with range as a variable, would require a fairly complex effort for the microprocessor and a large block of time, it was decided to use a look-up table to relate the two.




FIGURE 5. Optical system for demonstration unit.

RANGE-TIME RELATIONSHIP: The range measurement used in the focus command table comes from the microprocessor's on-board timer. It actually measures the time between the start of the transmitter and the received echo. For the system in question the timer counts pulses at the rate of one every 80 usec. (6) from an internal clock. For sound traveling at 13548 inches/sec., this gives a theoretical range/count relationship of:

$$\text{RANGE(inches)} = 0.54 * \text{COUNT}$$

Actual measurement of the system produced a slightly modified equation:

$$\text{RANGE(inches)} = -0.36 + 0.55 * \text{COUNT}$$

The offset error (-0.36 inches) may be due to the uncertainties in the start of the ultrasonic transmission and the timer or from inaccurate range measurements.

Figure 6 shows this experimentally obtained relationship.


FOCUS TABLE: Refer to figure 7. To obtain the final range/focus command (R/FC) table, a theoretical curve was first derived. It is based on a measured maximum of  $\pm 7$  volts output from the feedback potentiometer. The resulting curve is given in figure 7. This curve is very sensitive

FIGURE 6

RANGE/COUNT RELATIONSHIP

$$\text{COUNT} = 0.65 + 1.82 \text{ RANGE}$$

$$\text{RANGE} = -0.36 + 0.55 \text{ COUNT}$$






FIGURE 7  
Voltage for focus command (DAC output,  
manual, and theoretical) vs. Range.

to small errors in L1, F1, and F2. Thus, when the theoretical focus table was loaded into the EPROM (8748), it was found that a good focus was not achieved over the entire range of interest.

A qualitative measurement was then made by focusing the optical system by eye and measuring the feedback potentiometer output. After repeating this experiment several times, a band of acceptable focus points for each range was obtained. This is indicated by the two solid curves in figure 7.

Values within these curves were then chosen for the focus table, converted to the appropriate DAC input and loaded into the EPROM. After several minor adjustments, this method produced a focus command which gave good results over the entire range. The final points entered in the focus table are the dark circles in figure 7.

### 2.3 FOCUS TABLE ADJUSTMENTS

The focus commands stored in the focus table (page 03 of the 8748 EPROM), are dependent on the particular mechanical relationship between the ultrasonic microphone, which detects the range, and the optical system, which focuses on the subject. To allow for differences in this relationship, five possible adjustments exist.

1. For each situation reprogram the 8748. This would entail a lengthy initial set-up procedure in which the focus voltages are measured, converted to a digital command and "burned" into the EPROM. Once done it would not have to be repeated for a particular installation.
2. Mechanically adjust the relationship (fine tune) between the microphone and the lens for the best focus over the ranges anticipated. At extremes, there will be focus errors.
3. Adjust the DAC offset potentiometer (to be discussed when the electronics are described). This shifts the focus curve, figure 7, up and down. Again this adjustment may be satisfactory over limited ranges, but will not be good at the extremes.
4. Adjust the focus table entry point by adding or subtracting a fixed amount; i.e., increment/decrement the range count. This moves the focus curve left or right and at extreme ranges again may result in excessive errors. A combination of 3 or 4 may give better results. Option 3 is a simple screwdriver adjustment. Option 4 requires only a simple program change, but will necessitate "burning" a new program into the EPROM for each adjustment. Like 1, once done it need not be repeated.

5. Store the focus table in RAM. The table would be entered at start-up for each run. It would therefore require a one-time initialization procedure. Also it would mean a significant design change of the electronics to allow proper interfacing with and data transfer from the mainframe computer.

Procedure 5 gives the greatest flexibility. Number 1 is the next best permanent option. 3 and 4 combined require the same effort as 1. All things considered, procedure 2 appears to be the simplest method to adjust the system for different experimental set-ups. This method was used during the design stages.

#### 2.4 ELECTRONIC CIRCUIT

The front end of the automatic focus control unit consists of a commercial ranging system, figure 8. This system emits a 60, 57, 53, and 50 kHz sequential ultrasonic signal from a capacitive microphone. The transceiver board, powered by a user supplied 6V, 3A source, provides both the "start of transmit" signal and the "echo received" signal. Details of the operation can be found in reference 5.

The transceiver is controlled by a multivibrator built from a 74C14 Schmidt inverter and the 2N4401/2N2907 buffer.






FIGURE 8. Interface circuit for Polaroid Ultrasonic Range Measuring System. From Polaroid Handbook.

) When the INITIATE TRANSMIT PULSE goes high, the transceiver board is activated and after a brief period (less than 1 msec.) the ultrasonic signal is started and maintained for about 1 msec. This action is detected in pin 16, buffered by the 2N4401, and sent to the microprocessor.

The echo signal, when detected, causes a high pulse at pin 15. This signal is also buffered by a 2N4401 and then used to drive the microprocessor.

) Figure 9 shows the digital portion of the control board. The start and echo signals drive separate 74123's, dual monostables. The input signals initiate a 1 millisecond pulse from each package's first monostable; which, on its rising edge, activates the respective second monostable. A 10 usec. pulse is then available on pins 5 or 12. Pin 5 is a positive pulse (Q) and drives the microprocessor input T $\emptyset$  (used to start the on-board times). Pin 12 is a  $\bar{Q}$  pulse which is used to interrupt,  $\overline{INT}$ , the microprocessor and stop the timer. The initial 1 msec monostable is used to block false start and echo signals that may appear on the lines due to echos from multiple targets or other noise sources.

) The only manual control of the microprocessor is a reset button which, among other things, sets the program counter to 00<sub>H</sub>. A 6 MHz crystal controls the instruction cycle time and the on-board times. Two of the three available ports on the 8748 are used; one (Port 2) is tied to a

FIGURE 9. Part 1, microcomputer board. Pulse shaping (74123), microcomputer (8748), and DAC (1408 - 741).

display which will not be necessary in the final oculometer design, and the other (Port 1) outputs the digital focus command (FC).

FC is converted to analog form by an 8 bit DAC 1408. This DAC output is a 0 to -2 mA current which through a 741 op-amp is converted to an appropriate voltage as determined by the feedback resistor. The 10K potentiometer serves to provide bipolar operation from the DAC by biasing the op-amp so that with a  $80_H$  input, the op-amp output is 0 V. This gives an offset binary code operation.

The analog signal (FC) is next used as a command signal to a standard position feedback circuit, figure 10. If the operator desires, the FC signal can be derived from a manually controlled potentiometer. In either case this signal is compared to the feedback signal generated by the potentiometer connected to the motor shaft. When there is an error signal, it is amplified by the two 741's and used to drive a complementary pair (NPN-2222 and PNP-2N2907). This pair in turn controls the current to the servomotor. Feedback from the top of the motor to the second 741 serves to reduce the dead zone created by the complementary transistors.

An LED indicator is also provided to inform the operator when the system is not responding to the FC command (manual or automatic). Two LM311's (comparators) set limits so that an error greater than  $\pm 0.1$  volts will turn on the LED.




FIGURE 10. Electronic controller and focus error indicator circuits.

The motor, gears, lens carriage, and mount were provided by the Flight Dynamics and Control Division, Langley Research Center, Hampton, VA.

The final circuit, figure 11, consists of a 74C48, BCD to 7 segment driver, three 7 segment displays and three 2N2222's used as switches. Port 2's lower 4 bits provide the BCD code while bits 4, 5, and 6 respectively turn on the units, tens, and hundreds display digits.

The final figure of this section, figure 12, shows the cable connections for the power supply and servo unit.

## 2.5 SOFTWARE

The heart of the automatic focus control unit is 8747 microcomputer on a chip. This unit has a 1K EPROM program memory, 64 byte data RAM, one on-board timer, and 27 pin I/O arranged as three 8 bit ports and three test pins.

In establishing the memory map, figure 13, the RAM is divided into two memory banks, RB0 and RB1. RB0 is used to store the range count (COUNT) from the timer, calculate the digitally filtered output (OUT), and store the previous output. RB1 is used to convert the binary to decimal and then to BCD and finally output the 3 digit display control signal.

The 1K EPROM contains all the permanent software(8). In




FIGURE 11. Display circuit. Input from Port 2, 8748 via flat 16 conductor cable.





FIGURE 12. Power cable and servo cable pin connection



# MEMORY MAP




FIGURE 13.  
Oculometer automatic focus  
memory map.

page 00 is the main program. Figure 13 shows where the subroutines are located. This map can be compared with the flow chart in figure 4. Page 03 contains the focus table which is used to generate the proper focus command, given the range count (OUT(1)).

The digital filter uses a simple algorithm

$$\text{OUT}(I) = (\text{OUT}(I-1) + 0.25 (\text{COUNT}(I) - \text{OUT}(I-1)))$$

The 0.25 multiplier was used because of the ease with which it can be implemented; i.e., double shift right. It was determined after experimentally trying other  $2^{-n}$  factors.

In the focus table, ranges from about 19" to 50" are allowed. Closer than 19" the lens carriage will have reached its limit. Ranges greater than 50" produce a count greater than 90 and are thus rejected. In this case the lens carriage is near its other limit and will remain so until the target range is less than 50".

The remaining pages of this section contain the program stored in the 8748. The format gives the line number in column 1, the memory address in column 2, either the hex machine code or data in column 3, column 4 is a label, the mnemonic is in column 5 and lastly in column 6 are comments.

The details of the program are explained by the contents.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57

RANGE/FOCUS PROGRAM FOR OCULOMETER

AUTOMATIC FOCUS USING INTEL 8748

1-18-82, WJG

FORMAT-ADDRESS/DATA OR INSTRUCTION/LABEL/MNEMONIC/COMMENT

\*\*\*\*\* INITIALIZE/START/TIME \*\*\*\*\*

LOCATIONS 00-08 USED FOR RESET, INTERRUPT, AND TIMER OVERFLOW VECTORS.

00 04	RESET	JMP	JUMP TO INITIALIZE - CLEAR
01 10		INITIALIZE	REGISTERS.
02 00			
03 04	INTER	JMP	JUMP TO INTERRUPT SERVICE -
04 30		STOP	STOP TIMER.
05 00			
06 00			
07 04	TOVER	JMP	TIMER OVERFLOW-OUT OF RANGE
08 20		START	BEGIN AGAIN.

10 27	INITIAL	CLR A	CLEAR REGISTERS
11 AA		MOV R2,A	R2=COUNT INTEGER
12 AB		MOV R3,A	R3=COUNT DECIMAL
13 AC		MOV R4,A	R4=OUT INTEGER.
14 AD		MOV R5,A	R5=OUT DECIMAL
15 AE		MOV R6,A	R6=(COUNT(I)-OUT(I-1)) INTEGER
16 AF		MOV R7,A	R7=(COUNT(I)-OUT(I-1)) DECIMAL
17 04		JMP	BEGIN
18 20		START	

58				
59				
60	20	27	START	CLR A
61	21	62		MOV T,A
62	22	04		JMP
63	23	A0		SHOW
64	24	55	TIME	STRT T
65	25	05		EN I
66	26	C5		SEL RB0
67	27	04		JMP
68	28	80		DISPLAY
69				
70				
71				
72				
73	30	65	STOP	STOP TCNT
74	31	15		DIS I
75	32	C5		SEL RB0
76	33	42		MOV A,T
77	34	AA		MOV R2,A
78	35	03		ADD A,#26
79	36	26		
80	37	F2		JB7
81	38	3B		LIMIT
82	39	04		JMP
83	3A	3E		FILTER
84	3B	23	LIMIT	MOV A,#5A
85	3C	5A		
86	3D	AA		MOV R2,A
87	3E	FB	FILTER	MOV A,R3
88	3F	37		CPL A
89	40	6D		ADD A,R5
90	41	37		CPL A
91	42	AF		MOV R7,A
92	43	FA		MOV A,R2
93	44	37		CPL A
94	45	7C		ADDC A,R4
95	46	37		CPL A
96	47	AE		MOV R6,A
97	48	85		CLR F0
98	49	B8		MOV R0,#02
99	4A	02		
100	4B	E6		JNC
101	4C	4E		SHIFT
102	4D	95		CPL F0
103				
104				
105				
106				
107				
108				
109				
110				
111				
112				
113				
114				

CLEAR ACCUMULATOR  
 SET TIMER TO ZERO  
 JUMP TO DISPLAY OUTPUT WHILE  
 WAITING FOR TRANSMIT START  
 START TIMER  
 ENABLE INTERRUPT TO STOP TIMER  
 ON ECHO RETURN  
 JUMP TO CALCULATE NEW RANGE  
 COUNT DISPLAY

STOP TIMER  
 PREVENT FALSE ECHOS  
 R2=COUNT(I)  
 CHECK COUNT LIMIT > 90  
 IF COUNT > 90 SET LIMIT  
 IF NOT, FILTER  
 SET COUNT =90

R3=DECIMAL COUNT=00H  
 R5=DECIMAL OUT(I-1)  
 R7=DECIMAL (COUNT(I)-OUT(I-1))  
 R2=INTEGER COUNT(I)  
 R4=INTEGER OUT(I-1)  
 R6=INTEGER (COUNT(I)-OUT(I-1))  
 SET F0 WHEN (COUNT(I)-OUT(I-1))<0

115				
116				
117				
118				
119	4E 97	SHIFT	CLR C.	DIVIDE (COUNT(I)-OUT(I-1)) BY
120	4F FE		MOV A,R6	4 WITH 2 RIGHT SHIFTS
121	50 67		RRA C	
122	51 AE		MOV R6,A	
123	52 FF		MOV A,R7	
124	53 67		RRA C	
125	54 AF		MOV R7,A	
126	55 E8		DJNZ R0	
127	56 4E		SHIFT	
128	57 B6		JF0	ADJUST INTEGER PART IF DIFFERENCE
129	58 5B		SUB	NEGATIVE
130	59 04		JMP	OTHERWISE ADD
131	5A 5F		ADD	
132	5B FE	SUB	MOV A,R6	INTEGER ADJUST
133	5C 43		ORL A,#C0	
134	5D C0			
135	5E AE		MOV R6,A	COMPLETE FILTER ADDITION
136	5F FD	ADD	MOV ,R5	OUT(I)=OUT(I-1)+0.25*(COUNT(I)-
137	60 6F		ADD A,R7	OUT(I-1))
138	61 AD		MOV R5,A	
139	62 FC		MOV A,R4	STANDARD FIRST ORDER FILTER
140	63 7E		ADDC A,R6	WITH TF=TS
141	64 AC		MOV R4,A	
142	65 E3		MOVP3 A,#A	FIND FOCUS COMMAND
143	66 39		OUTL P1,A	OUTPUT COMMAND
144	67 04		JMP	DO IT AGAIN
145	68 20		START	
146				
147				
148				
149				
150				
151				
152	80 FA	DISPLAY	MOV A,R2	PUT COUNT(I) INTO ACCUMULATOR
153	81 D5		SEL RB1	WORK IN REGISTER BANK 1
154	82 AB		MOV R0,0	R0=REMAINDER STORAGE
155	83 BF		MOV R7,#40	R7=HUNDREDS OUTPUT/CONTROL
156	84 40			40H=CONTROL
157	85 BE		MOV R6,#20	R6=TENS OUTPUT/CONTROL
158	86 20			20H=CONTROL
159	87 BD		MOV R5,#10	R5=UNITS OUTPUT/CONTROL
160	88 10			10H=CONTROL
161	89 BC		MOV R4,#9C	R4=HUNDREDS SUBTRACTOR
162	8A 9C			
163	8B BB		MOV R3,#F6	R3=TENS SUBTRACTOR
164	8C F6			
165				
166				
167				
168				
169				
170				
171				

172				
173				
174				
175				
176				
177				
178				
179				
180				
181	8D 6C HUNDRED	ADD A,R4	SUBTRACT 100 FROM COUNT, IN-	
182	8E E6	JNC	CREMENT HUNDREDS COUNTER IF	
183	8F 94	TENS	SUBTRACTION SUCCESSFUL. CON-	
184	90 AB	MOV R0,A	TINUE. OTHERWISE GO TO TENS.	
185	91 1F	INC R7		
186	92 04	JMP		
187	93 8D	HUNDREDS		
188	94 F8 TENS	MOV A,R0	SAME AS BEFORE EXCEPT FOR	
189	95 6B	ADD A,R3	TENS.	
190	96 E6	JNC		
191	97 9C	UNITS		
192	98 AB	MOV R0,A		
193	99 1E	INC R6		
194	9A 04	JMP		
195	9B 94	TENS		
196	9C FD UNITS	MOV A,R5	REMAINDER IS UNITS, ADD TO	
197	9D 68	ADD A,R0	R5.	
198	9E AD	MOV R5,A		
199	9F 00	NOP		
200				
201				
202				
203				
204				
205	A0 D5 SHOW	SEL RB1	SELECT REGISTER BANK 1 WITH	
206	A1 FF	MOV A,R7	DISPLAY DATA AND CONTROL	
207	A2 3A	OUTL P2,A	OUTPUT HUNDREDS	
208	A3 14	CALL		
209	A4 B0	DELAY		
210	A5 FE	MOV A,R6		
211	A6 3A	OUTL P2,A	OUTPUT TENS	
212	A7 14	CALL		
213	A8 B0	DELAY		
214	A9 FD	MOV A,R5		
215	AA 3A	OUTL P2,A	OUTPUT UNITS	
216	AB 14	CALL		
217	AC B0	DELAY		
218	AD 04	JMP	DO IT AGAIN	
219	AE A0	SHOW		
220				
221				
222				
223				
224				
225				
226	B0 27 DELAY	CLR A	DISPLAY DIGIT	
227	B1 17 X	INC A		
228	B2 36	JT0	IF TO HIGH, START TIMER	

229	B3 24	TIME	
230	B4 96	JNZ	OTHERWISE, CONTINUE THE
231	B5 B1	X	DISPLAY
232	B6 93	RETR	

1 300 00 RANGE RANGE/COUNT DATA FOCUS CONTROL DATA AT COUNT  
2 ↓ ADDRESS, PAGE 3 OF MEMORY.  
3  
4 321 00  
5 322 1D 18.5"/34  
6 323 3A 19.0"/35  
7 324 3F  
8 325 46 20.0"/37  
9 326 4A  
10 327 4F 21.0"/39  
11 328 54  
12 329 5A 22.0"/41  
13 32A 5C  
14 32B 62 23.0"/43  
15 32C 6A 24.0"/44  
16 32D 6C  
17 32E 70 25.0"/46  
18 32F 74  
19 330 78 26.0"/48  
20 331 79  
21 332 7B 27.0"/50  
22 333 7D  
23 334 80 28.0"/52  
24 335 83 29.0"/53  
25 336 86  
26 337 89 30.0"/55  
27 338 8A  
28 339 8C 31.0"/57  
29 33A 8D  
30 33B 8F 32.0"/59  
31 33C 91  
32 33D 93 33.0"/61  
33 33E 95  
34 33F 98 34.0"/63  
35 340 9A 35.0"/64  
36 341 9B  
37 342 9C 36.0"/66  
38 343 9E  
39 344 A0 37.0"/68  
40 345 A1  
41 346 A2 38.0"/70  
42 347 A3  
43 348 A4 39.0"/72  
44 349 A5 40.0"/73  
45 34A A6  
46 34B A7 41.0"/75  
47 34C A8  
48 34D A9 42.0"/77  
49 34E AA  
50 34F AB 43.0"/79  
51 350 AC  
52 351 AD 44.0"/81  
53 352 AE  
54 353 AF 45.0"/83  
55 354 B0  
56 355 B1 46.0"/85  
57 356 B2 47.0"/86



58	357 B3	
59	358 B4	48.0"/88
60	359 B4	
61	35A B5	
62	35B B5	
63	35C B6	
64	35D B6	
65	35E B7	
66	35F B7	
67	360 00	
68	↓	
69		
70	380 00	
71		

### 3. TRACKING CONTROL

One of the major improvements which could be made in the present oculometer system is a better search routine. This task now takes valuable time from data acquisition.

When the subject's eye image is lost, the software drops into a locate and verify process. To accomplish this, the mirror control unit is directed to search in a small area by scanning in the X direction, the incrementing in Y and repeating the X scan. If the small search area is not fruitful, a larger area is searched. This process is repeated (X-Y scan) until an eye image with round pupil and corneal highlight is obtained. It is then verified and only then can valid look point data be collected. The search process is not always successful. When this happens, large blocks of time are used in repetitiously repeating the same X-Y scan pattern.

If the eye and/or head moves slightly, so that the image stays in the picture, minor adjustment in the mirror position are made by the software. These attempts to keep the pupil center in the TV picture. This segment of the oculometer's operation works well.

The purpose of the unit developed for head tracking is to supplement the oculometer when a search is necessary. It does not replace the fine adjustments made when the eye is centered. The unit will basically tell the computer where the head is located and direct the mirrors to that location by using X-Y ultrasonic ranging systems. By employing a known offset, the eye can be found. The geometry of the system's operation is shown in figure 14.

### 3.1 SYSTEM OVERVIEW

HARDWARE: Refer to figures 14 and 15. The overall system operation originates at the rate controller which alternately switches between the X and Y ultrasonic systems. The ultrasonic system is the same (7) as used in the automatic focusing unit. Both the X and Y ultrasonic boards are buffered to give compatible signals to the wave-shaping circuit and microprocessor.

The only difference between the focusing unit's ultrasonic operation and the head tracking system is the X-Y rate controller. Its signal, a 200 msec. square wave, is fed into the microprocessor as well as the ultrasonic units. When high, a Y distance measurement is being made. A low level indicates that the X direction is being measured. Thus, once every 200 msec., the X transmitter




FIGURE 14. Tracking system geometry.




FIGURE 15. Automatic Tracking System block diagram.

is turned on for about 1 msec.; the receiver then waits for an echo for 100 msec. The X unit is then turned off and the same operation repeated for Y.


Three signals, START of transmission, ECHO received, and X-y Direction indicator are fed into the microcomputer. This information is processed and outputted on Port 1 for X and Port 2 for Y. The 8 bit output signals are converted to analog form by two DAC's.

The analog signal is now fed to a power amplifier which converts the voltage input to a current output. Where in turn it drives two orthogonal galvanometer motors. The mirrors, motors, and their housing were also supplied by NASA. This last link in the system directs the IR beam to the target.

There is a provision to manually control the mirrors with a "joy stick." Voltage for the joy stick is from a  $\pm 1.25V$  regulated supply. Also, the system can be manually reset.

SOFTWARE: Figure 16 gives the flow chart for the software programmed into the EPROM memory of the microcomputer.

After a manual RESET, the program jumps to INITIALIZE where registers are cleared and the X-Y offset loaded. Note that for different mirror-microphone relationships, these values would have to be changed, see figure 14.






FIGURE 16. Automatic Tracking System flow chart.



The particular offset presently loaded is for 19" in the Y direction and 27" in the X direction.

The program now jumps to START where the target range is next stored. This is also fixed in the demonstration unit at 36", but could be constantly updated by the automatic focusing unit if the same microcomputer controlled all functions (see Conclusions). The Timer is cleared and the system put into an idle mode until  $T_0$  goes high.  $T_0$  corresponds to the START of the ultrasonic transmission. The Timer is started and, while waiting for the ECHO, and X-Y flag is set to indicate which direction is being measured. The flag is controlled by T1 which is reading the high-low status of the ultrasonic rate controller.

When the INTERRUPT goes low, meaning that an ECHO has been received, the Timer is STOPPED and the distance count stored.

The DIFFERENCE between the offset X/Y and the measured distance x/y is next calculated. A flag  $F_0$  is set for a negative result.

To find the angle,  $\theta$ , which controls the mirrors movement, the DIVIDE routine is used (9). The approximation

$$\theta \approx \sin \theta \approx \frac{\text{distance}}{\text{hypotenuse}}$$

is used in this algorithm since the angles will be less than  $\pm 14^\circ$ . For the particular application

$$\begin{aligned} \theta_x &= (X - x)/\text{Range} \\ \text{or} \quad \theta_y &= (Y - y)/\text{Range} \end{aligned}$$

The output of this computation is in a sign(FØ) -magnitude format. To correctly operate the digital to analog converter, an offset binary is required. The transformation between the two is provided by CONVERT (and a potentiometer setting).

The program next drops down to OUTPUT which latches the command  $\theta$  into Ports 1 or 2 if the measurement was X or Y respectively. The program then branches back to START and recycles through the entire operation.

Should there be a Timer overflow due to the lack of a target (no ECHO), the program will also return to the START routine to continue its cycle.

### 3.2 ELECTRONIC CIRCUIT

The electronic circuit diagrams for the head tracking system are shown in figures 17 through 22.





FIGURE 17. X ultrasonic board with buffer and rate controller.

Figure 17 is the X ultrasonic unit. It is mounted so as to measure target motion in the X direction only. It consists of an ultrasonic ranging system board with a capacitive microphone and a buffer circuit as shown. This is a speed up circuit which allows pulsing at a 50 msec rate. Note that the START and ECHO signals swing between 0 to 5 volts. These are fed to the wave shaping network. Also included in the X ultrasonic unit is the multivibrator rate controller for alternating X and Y measurements. This made from a 74C14 and a simple RC timer. The  $X_c$  signal likewise controls the Y unit and is used as an input to the microprocessor.

Figure 18 is the ultrasonic Y unit and is identical to the X unit except that no rate controller is present.

In figure 19 the START and ECHO signals from X and Y are fed into NOR gates which output a pulse when transmission starts and an echo is received. The pulses are used to trigger the 74123's dual monostables. The first monostables in each 74123 is set to about 10 msec. The second, driven by the first, gives only a 20 usec pulse which drives the microprocessor. The first monostable time is long in order to isolate the microprocessor from noise and false echos (from multiple targets). The START signal triggers the  $T_0$  pin and the ECHO signal triggers the  $\overline{INT}$  pin. A 6MHz crystal controls the speed of operation of the processor and the timer.





The RESET switch discharges the capacitor through a 1K to force the reset pin low. The T1 input is from  $Y_c$  which signals the processor as to which direction, X or Y, is being measured. The output Port 1 is to the X mirror control, while Port 2, divided into two 4 bit nibbles, controls the Y mirror.

In figure 20 the outputs from the 8748 drive two 1408 DAC's that are set up for bipolar operation. The 8 bit input is converted to a 0 to -2mA output. This is combined with currents from a 5 volt source through a 22K and 10K pot. One-half a 4558 op-amp is used for each direction to convert the current to an output voltage. The 22K-10K pot parallel combination allows adjustment to the reference position in a manner similar to that provided by the X-Y offset value.

Figure 21 shows the regulated voltage source for the manual joy stick control. It is composed of an LM317 (positive voltage) and LM337 (negative voltage) adjustable voltage regulators. The input to the circuit is  $\pm 15V$ , its output  $\pm 1.25V$ . A switch allows selection between manual and automatic control. The  $X_{out} - Y_{out}$  is connected to the driver amplifiers.

Finally figure 22 gives the pin connections for the interconnecting cables. The first, a 10 conductor ribbon cable, is for the X-Y START/ECHO signals, the direction signal, and a 5V source. The other cable carries the 6V for the ultrasonic boards.




FIGURE 20. DAC output (1408 - 4558)






FIGURE 21. Regulated supply for manual joy stick control.

8 PIN PLUG

1	BLACK	5V gd.
2	WHITE	+5V
3	GRAY	Y ECHO
4	PURPLE	Y START
5	BLUE	x/y MEASUREMENT
6	BROWN	X ECHO
7	RED	X START

4 PIN PLUG

2	BLACK	6V gd.
4	BLACK	+6V

FIGURE 22. Cable connections for  
Automatic Tracking System.

### 3.3 SOFTWARE

The program memory as shown in figure 23 is divided into various routines which correspond to those shown in the flow chart, figure 16. The entire program takes up less than 1 page of memory and can even be condensed further if all the routines were compacted one directly behind the other.

The on-board registers are used as indicated in figure 23. In register bank 0, RB0, register R0 is the flag which points to X or Y data as determined by the  $Y_c$  signal. R1 points to the divisor for the divide routine. This is R7 in the demonstration unit. R7 contains the range information. R1 also points to the X or Y offset (R34 or R35) during the DIFF routine. R2 is the dividend and R3 a counter for the DIVIDE routine. R3 is also a temporary storage location during OUTPUT.

R32 and R33 store the most recent X and y measured distances respectively. R34 and R35, the X and Y fixed offset, must be altered if the relationship between the mirrors and the ultrasonic microphones is changed.

The remainder of this section is the actual program stored in the EPROM of the 8748. Comment statements describe its operation. The format is the same for the automatic focus control unit Software discussion.

## MEMORY MAP

### PROGRAM MEMORY

PAGE 0	00H	VECTORS FOR RESET, INTERRUPT TIMER OVERFLOW
	10H	INITIALIZE
	30H	START
	50H	WAIT
	60H	STOP
	70H	DIFF
	90H	DIVIDE
	C0H	CONVERT
	D0H	OUTPUT

### REGISTERS

RB0	0H	x/y POINTER
	1H	DIVISOR POINTER/X,Y OFFSET
	2H	DIVIDEND
	3H	COUNTER/OUTPUT STORAGE
	7H	RANGE COUNT
	32H	x COUNT
	33H	y COUNT
	34H	X OFFSET
	35H	Y OFFSET

FIGURE 23. Automatic Tracking System  
memory map.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57

MIRROR CONTROL PROGRAM FOR OCULOMETER

AUTOMATIC HEAD TRACKING USING INTEL 8748

4-30-82, WJG

FORMAT-ADDRESS/DATA OR INSTRUCTION/LABEL/MNEMONIC/COMMENT

\*\*\*\*\*

LOCATION 00-08 USED FOR RESET, INTERRUPT, AND TIMER OVERFLOW VECTORS.

00	04	RESET	JMP	JUMP TO INITIALIZE
01	10		INITIALIZE	
02	00			
03	04	INTER	JMP	JUMP TO INTERRUPT SERVICE
04	60		STOP	STOP TIMER
05	00			
06	00			
07	04	TOVER	JMP	JUMP TO START - TIMER OVERFLOW
08	30		START	OUT OF RANGE.

10	27	INIT	CLR A	CLEAR ACCUMULATOR
11	A9		MOV R1,A	CLEAR REGISTERS R1 TO R7
12	AA		MOV R2,A	
13	AB		MOV R3,A	
14	AC		MOV R4,A	
15	AD		MOV R5,A	
16	AE		MOV R6,A	
17	AF		MOV R7,A	
18	B8		MOV R0,#34	R0 IS POINTER TO R34
19	34			
1A	B0		MOV @R0,#32	32 TO R34 (X OFFSET=27")
1B	32			
1C	18		INC R0	R0=35
1D	B0		MOV @R0,#23	23 TO R35 (Y OFFSET=19")
1E	23			
1F	04		JMP	
20	30		START	

```

58
59
60
61
62
63
64
65
66
67      30 BF START      MOV R7,#42      R7=RANGE COUNT, SET AT 36"
68      31 42
69      32 27 TIMSTRT    CLR A          CLEAR ACCUMULATOR
70      33 62           MOV T,A        SET TIMER TO ZERO
71      34 26 IDLE       JNT0          IDLE UNTIL TO HIGH
72      35 34
73      36 55           STRT T         START TIMER
74      37 00           NOP
75      38 56           JT1           SET X/Y FLAG
76      39 3E           YFLG
77      3A B8 XFLG       MOV R0,#32     X MEASUREMENT, R0=32
78      3B 32
79      3C 04           JMP           JUMP TO INTERRUPT WAIT
80      3D 50           WAIT
81      3E B8 YFLG       MOV R0,#33     Y MEASUREMENT, R0=33
82      3F 33
83      40 04           JMP
84      41 50           WAIT
85
86
87
88      50 86 WAIT       JNI           WAIT HERE FOR INTERRUPT
89      51 60           STOP
90      52 04           JMP
91      53 50           WAIT
92
93
94
95
96
97      60 65 STOP       STOP TCNT      STOP TIMER
98      61 00           NOP
99      62 00           NOP
100     63 42           MOV A,T        MOVE COUNT TO ACCUMULATOR
101     64 A0           MOV @R0,A      STORE X/Y COUNT IN R32/R33
102     65 04           JMP           JUMP TO DIFFERENCE
103     66 70           DIFF
104
105
106
107
108
109
110
111
112
113
114

```

115	70 F8 DIFF	MOV A,R0	MOVES X/Y POINTER TO ACCUMULATOR
116	71 17	INC A	POINTS TO X/Y OFFSET REGISTER
117	72 17	INC A	
118	73 A9	MOV R1,A	OFFSET POINTER IN R1
119	74 F0	MOV A,@R0	ACCUMULATOR=X/Y
120	75 37	CPL A	
121	76 17	INC A	ACCUMULATOR=-X/Y
122	77 61	ADD A,@R1	ACCUMULATOR=(X-X) OR (Y-Y)
123	78 F6	JC	
124	79 80	PLUS	
125	7A 37 MINUS	CPL A	
126	7B 17	INC A	ACCUMULATOR=/(X-X)/ OR /(Y-Y)/
127	7C 85	CLR F0	
128	7D 95	CPL F0	SET F0 F0 R NEGATIVE RESULT
129	7E 04	JMP	GO TO DIVIDE
130	7F 90	DIVIDE	
131	80 85 PLUS	CLR F0	CLEAR F0 FOR POSITIVE RESULT
132	81 04	JMP	GO TO DIVIDE
133	82 90	DIVIDE	
134			
135			
136			
137			16 BIT BY 8 BIT FIXED POINT UN-
138			SIGNED DIVISION.
139			R1 POINTS TO DIVISOR REGISTER
140			MS BYTE IN ACCUMULATOR
141			LS BYTE IN R2
142	90 B9 DIVIDE	MOV R1,#07	
143	91 07		
144	92 BB	MOV R3,#08	
145	93 08		
146	94 37	CPL A	
147	95 61	ADD A,@R1	
148	96 37	CPL A	
149	97 F6	JC	
150	98 9C	DIVIA	
151	99 A7	CPL C	
152	9A 04	JMP	
153	9B B5	DIVIB	
154	9C 61 DIVIA	ADD A,@R1	
155	9D 97 DIVILP	CLR C	
156	9E 2A	XCH A,R2	
157	9F F7	RLC A	
158	A0 2A	XCH A,R2	
159	A1 F7	RLC A	
160	A2 E6	JNC	
161	A3 A9	DIVIE	
162	A4 37	CPL A	
163	A5 61	ADD A,@R1	
164	A6 37	CPL A	
165	A7 04	JMP	
166	A8 B1	DIVIC	
167			
168			
169			
170			
171			

172	A9 37	DIVIE	CPL A	
173	AA 61		ADD A, @R1	
174	AB 37		CPL A	
175	AC E6		JNC	
176	AD B1		DIVIC	
177	AE 61		ADD A, @R1	
178	AF 04		JMP	
179	B0 B2		DIVID	
180	B1 1A	DIVIC	INC R2	
181	B2 EB	DIVID	DJNZ R3	
182	B3 9D		DIVILP	
183	B4 97		CLR C	
184	B5 2A	DIVIB	XCH A, R2	
185	B6 04		JMP	RESULT IN ACCUMULATOR
186	B7 C0		CONVERT	
187				
188				
189				
190				
191				
192	C0 B6	CONVER	JF0	CONVERSION FROM SIGN MAGNITUDE TO
193	C1 C7	POS	NEG	OFFSET BINARY. JUMP TO NEGATIVE.
194	C2 97		CLR C	
195	C3 A7		CPL C	COMPLIMENT SIGN BIT
196	C4 67		RRC A	MOVE OFFSET BINARY TO ACCUMULATOR
197	C5 04		JMP	GO TO OUTPUT
198	C6 D0		OUTPUT	
199	C7 97	NEG	CLR C	CLEAR CARRY (SIGN BIT) FOR NEGATIVE
200	C8 37		CPL A	
201	C9 17		INC A	CONVERT SIGN-MAGNITUDE TO OFFSET BINARY
202	CA 67		RRC A	MOVE OFFSET BINARY TO ACCUMULATOR
203	CB 04		JMP	
204	CC D0		OUTPUT	
205				
206				
207				
208				
209				
210	D0 2B	OUTPT	XCH A, R3	STORE COMMAND IN R3
211	D1 F8		MOV A, R0	
212	D2 12		JB0	JUMP IF B0 SET (R0=33) AND THUS Y
213	D3 D8		YP2	
214	D4 2B	XP1	XCH A, R3	OUTPUT FROM R3
215	D5 39		OUTL P1, A	OUTPUT X COMMAND TO P1
216	D6 04		JMP	GO BACK TO BEGIN
217	D7 32		TIMSTR	
218	D8 2B	YP2	XCH A, R3	OUTPUT FROM R3
219	D9 3A		OUTL P2, A	OUTPUT Y COMMAND TO P2
220	DA 04		JMP	GO TO BEGIN
221	DB 32		TIMSTR	
222				
223				
224				
225				



#### 4. CONCLUSIONS

Both projects, automatic focusing and head tracking, have proved the feasibility of such an approach to the improvement of the oculometer system. Major tasks still exist if the schemes herein reported are to be successfully incorporated into the Langley oculometer.

First the ultrasonic boards should be redesigned for this specific application. The present system produces audible "clicks" as it turns on, can operate only at limited rates, and has a narrow ultrasonic beam. These problems could be eliminated with a custom ultrasonic ranging system.

A scheme to bounce the ultrasonic beam off the mirrors and thus have it travel along the same path as the IR beam would help the automatic focusing unit. This would insure that the range, and hence the focus control, is directed at the eye.

It is possible to incorporate both focusing and tracking systems into a single unit. Thus one 8748 could control both operations, thereby reducing the complexity of the total.

There is enough memory to do this, but some major hardware modifications would be necessary.

Integration of these systems with the oculometer should be a paramount consideration. The range data and mirror control information can be advantageously used by the minicomputer. It may even be possible to do some preprocessing of these signals to further unburden the minicomputer.

Finally, a simple initialization routine should be developed so different sites can easily be set up. This could be incorporated through minicomputer control or by the manual provisions contained on the focusing and tracking units.

## REFERENCES

- (1) Middleton, D. B. et al, "Description of Flight Tests of an Oculometer," NASA Technical Note D-8419, June 1977.
- (2) Spady, Amos A., Jr., "Airline Pilot Scan Patterns During Simulated ILS Approaches," NASA Technical Paper 1250, October 1978.
- (3) Fulton, C. L. and R. L. Harris, Sr., "Error Analysis and Corrections to Pupil Diameter Measurements with Langley Research Center's Oculometer," NASA Technical Memorandum, May 1980.
- (4) Waller, M. C. and M. A. Wise, "The Oculometer in Flight Management Research," paper, AIAA 14th Aerospace Science Meeting, Pasadena, CA, January 1975.
- (5) "Ultrasonic Ranging System," Polaroid Corp., Cambridge, Mass., Jan. 1980.
- (6) "MCS-48 Family of Single Chip Microcomputers User's Manual," Intel Corp., Santa Clara, Calif., August 1980.
- (7) "8048 Family Applications Handbook," Intel Corp., Santa Clara, Calif., January 1980.
- (8) "Prompt 48 Microcomputer User's Manual," Intel Corp., Santa Clara, Calif., 1978.

1. Report No. NASA CR-166007		2. Government Accession No.		3. Recipient's Catalog No.	
4. Title and Subtitle Oculometer Focus and Mirror Control				5. Report Date October 1982	
				6. Performing Organization Code	
7. Author(s) Warren J. Guy				8. Performing Organization Report No.	
9. Performing Organization Name and Address Department of Electrical Engineering Lafayette College Easton, PA 18042				10. Work Unit No.	
				11. Contract or Grant No. NAG1-45	
12. Sponsoring Agency Name and Address National Aeronautics and Space Administration Washington, DC 20546				13. Type of Report and Period Covered Contractor Report	
				14. Sponsoring Agency Code	
15. Supplementary Notes Langley technical monitor: Patrick A. Gainer Final Report (March 1, 1981 to April 30, 1982)					
16. Abstract  In order to adapt the oculometer used at Langley Research Center to the specific eyetracking tasks being investigated, various studies are underway. This report describes one of these, an automatic focusing system designed around an ultrasonic range measurement. Besides maintaining the focus, subject distance is a by-product which could lighten the computational effort. The other system which is discussed is an automatic head tracking unit. It is intended to reduce the search time required when track is lost. An X-Y ultrasonic measurement is also made in this system to control the deflection mirrors.					
17. Key Words (Suggested by Author(s)) Eye tracker Ultrasonic tracker Range measurements Automatic focusing				18. Distribution Statement  Unclassified - unlimited  Subject Category 35	
19. Security Classif. (of this report) Unclassified		20. Security Classif. (of this page) Unclassified		21. No. of Pages 68	
				22. Price A04	

**End of Document**